

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITIONCERTIFICATENo. 535

Date : \_\_\_\_\_

It is certified that an inspection team headed by CSI ANIL SIRSIYA

(Name of

Officers with designation) from NAGAR NIGAM (INDORE).PHED inspected the SHRI CLOTH MARKET VAISHNAV HR. SEC. SCHOOL(Name & Address of the school) on 20/02/2026 (date of inspection) and on thebasis of Water Test Report (Attached) bearing no. 447dated 26/02/2026 of SAIFUNIQUE TESTING LAB LLP(PHED Lab) certified that the SHRI CLOTH MARKET VAISHNAV HR. SEC. (Name of

school) has safe drinking water facilities for the students and members of staff of the

institution. School is also maintains the hygienic sanitation condition in the school

building &amp; the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above valid for a period of \_\_\_\_\_.

Signature with Seal :

  
प्रभारी मुख्य स्वास्थ्य निरीक्षक  
मालबहादुर शास्त्री डोन क्र. १

Name :

आनिल सिर्सिया

Designation :

Name & Address of the Office/ Department: NAGAR NIGAM INDORE.

To

THE PRINCIPALSHRI CLOTH MARKET VAISHNAV HR. SEC. SCHOOL177, SOUTH RAJMOHALLA, INDORE.

(Name &amp; Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

आयक

क्रमांक. 535.....

दिनांक 26.12.26

डोन क्रमांक-07



# SAIFUNIQUE

— TESTING LAB LLP —

PHARMACEUTICAL | FOOD | WATER | WASTEWATER |  
CORROSION | MICROBIOLOGY | SOIL | LAB TRAINING

[www.saifuniquetestinglab.com](http://www.saifuniquetestinglab.com) | [www.fatimasaifee.com](http://www.fatimasaifee.com)

An ISO 9001:2015 Certified Laboratory

## CERTIFICATE OF ANALYSIS

REPORT NO. 447		ISSUE DATE: 26/02/26	
ULR: -----			
1	Name of Customer	> Shree Cloth Market Vaishnav Higher Secondary School	
2	Address of Customer	> Rajmoholla Indore	
3	Letter Reference No.	> -	Letter Date: -
4	Sample Identification No.	> SUTL/0226/190	
5	Sample Description	> Drinking Water	
6	Location of Test Performed	> Permanent Facility	
7	Condition of Sample	> Good And satisfactory	
8	Date of Sample Receipt	> 20/02/26	
9	Date of Test Start	> 21/02/26	Date of Test Complete: 25/02/26
10	Environmental Conditions	> Temp. (°C) 25 (°C)	Humidity (55 %RH) 33%

S.no.	Test Parameter	Units	Results	Specification Limit	Test Method
01	Colour	-	Nil	Qualitative	Complies
02	Odour	-	Agreeable	Qualitative	IS-3025 (Part 5)
03	Taste	-	Agreeable	Qualitative	IS-3025 (Part 8)
04	pH	-	5.65	1 to 10	IS-3025 (Part 11)
05	Total Dissolved Solids	PPM	42.0	Max. 500.0	IS-3025 (Part 16)
06	Conductivity	µS/cm	76.0	Max. 500.0	IS-3025(Part 14)
07	Total Hardness	mg/L	8.3	Max. 200.0	IS-3025 (Part 21)
08	Turbidity	NTU	Less than 1.0	Max. 10.0	IS 3025 (Part 10)
09	Total Alkalinity	mg/L	30.0	Max. 200.0	IS 3025 (Part 23)

### NOTE:

1. The results shown in this test report only relate to the given samples tested unless stated otherwise.
2. The Report should not be reproduced in part or full unless granted special permission in writing by the company.

### Contact

+91 7869246023

### Email

info@saifuniquetestinglab.com

### Address

332-333, Veda Business Park, Near  
Apple Hospital, Bhawarkuan, Indore,  
452001



# SAIFUNIQUE

— TESTING LAB LLP —

PHARMACEUTICAL | FOOD | WATER | WASTEWATER |  
CORROSION | MICROBIOLOGY | SOIL | LAB TRAINING

[www.saifuniquetestinglab.com](http://www.saifuniquetestinglab.com) | [www.fatimasaifee.com](http://www.fatimasaifee.com)

An ISO 9001:2015 Certified Laboratory

## CERTIFICATE OF ANALYSIS

10	Calcium	mg/L	3.2	Max. 200.0	IS-3025 (Part 40)
11	Magnesium	mg/L	1.2	Max. 30.0	IS 3025 (Part 46)
12	Chloride (as Cl)	mg/L	20.0	Max. 250.0	IS 3025 (Part 32)
13	Nitrate	mg/L	0.9	Max.45.0	IS-3025 (Part 36)
14	Fluoride	mg/L	0.2	Max. 1.0	IS-3025 (Part 60)
15	Sulphate	mg/L	2.2	Max. 200	IS-3025 (Part 24)
16	Phosphate	mg/L	Not Detected	-	IS 10500:2012
17	Arsenic	mg/L	Not Detected	Max. 0.01	IS 10500:2012
18	Iron	mg/L	0.012	Max. 0.3	IS 10500:2012
19	Residual Free Chlorine	mg/L	Not Detected	Max.1.0	IS-3025 (Part 26)
20	MPN Coliform	-	Not Detected	Should be Absent	IS: 10500:2012
21	Faecal Coliform	-	Not Detected	Should be Absent	IS: 10500:2012
22	Manganese	mg/l	Below 0.01	Max. 0.1	IS 10500:2012

\*\*\*\* END OF REPORT \*\*\*\*

Checked by

Lokendra Borana



Authorized Signatory

Dr. K. Fatima Saifee

### NOTE:

1. The results shown in this test report only relate to the given samples tested unless stated otherwise.
2. The Report should not be reproduced in part or full unless granted special permission in writing by the company.

### Contact

+91 7869246023

### Email

info@saifuniquetestinglab.com

### Address

332-333, Veda Business Park, Near  
Apple Hospital, Bhawarkuan, Indore,  
452001